

EC - TYPE EXAMINATION CERTIFICATE

**Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

- 3 EC - Type Examination Certificate Number: **Baseefa13ATEX0231X**
- 4 Equipment or Protective System: **Type DB3B GD Sounder & DB4B GD Loudspeaker**
- 5 Manufacturer: **Cooper MEDC Limited**
- 6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**
- 7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential Report No. **GB/BAS/ExTR13.0247/00**
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN 60079-0: 2012**
EN 60079-1: 2007
EN 60079-31: 2009
- except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12 The marking of the equipment or protective system shall include the following :

⊕ II 2GD Ex d IIC T4 Gb (T_{amb} = -55°C to +70°C)*
Ex tb IIIC T135°C Db IP66 (T_{amb} = -55°C to +70°C)* *See Schedule

Baseefa Customer Reference No. 0676

Project File No. 12/0368

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



SGS Baseefa Limited

Rockhead Business Park, Sladen Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


P. S. SINCLAIR 
GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0231X

15 Description of Equipment or Protective System

The DB4B GD Loudspeaker may be rated up to 100V at either 8W, 15W or 25W and comprises a cylindrical body and two covers all moulded in Glass reinforced polyester. The front cover is an irregular shape which when fitted forms a chamber for the speaker driver assembly and is permanently sealed/filled with a potting compound. In the front of this cover is a fine stainless steel mesh pressed metal wire element to facilitate sound transmission.

The circular rear cover closes a flameproof chamber housing an assembly of a transformer and a control/terminal PCB. The cover is fixed with six M5 x 20mm long stainless steel socket head screws of grade A2-70 minimum. The screws are profiled to be retained within the rear cover during assembly/dis-assembly.

Up to two M20/M25 (or NPT equivalent) cable entries are provided in the side of the enclosure to accommodate suitably certified cable entry devices.

A plastic horn assembly (with either a long or short flare) is fitted externally to the front, and along the sides, of the enclosure, together with a mounting bracket. When the short flare is fitted the ingress protection rating is reduced to IP65.

The 8W units are marked with a T4/T135°C ($T_{amb} = -55^{\circ}\text{C}$ to $+70^{\circ}\text{C}$) and/or T5/100°C ($T_{amb} = -55^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -55^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

The 15W units are marked with a T4/T135°C ($T_{amb} = -55^{\circ}\text{C}$ to $+65^{\circ}\text{C}$) and/or T5/100°C ($T_{amb} = -55^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -55^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

The 25W units are marked with a T4/T135°C ($T_{amb} = -55^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T5/T100°C ($T_{amb} = -55^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

Variation 0.1

The DB3B GD Sounder is rated up to 254V, 15W and is identical in construction to the above Loudspeaker except that the flameproof chamber contains different components, including sound generating PCB's (with both AC & DC variants).

The Sounders are marked with a T4/T135°C ($T_{amb} = -55^{\circ}\text{C}$ to $+70^{\circ}\text{C}$) and/or T5/100°C ($T_{amb} = -55^{\circ}\text{C}$ to $+55^{\circ}\text{C}$) and/or T6/T85°C ($T_{amb} = -55^{\circ}\text{C}$ to $+40^{\circ}\text{C}$) Temperature Class/Ambient combination.

In addition the DB3B GD Sounder may optionally be marked with an alternative RB6-B GD type designation.

16 Report Number

Confidential Report Number GB/BAS/ExTR13.0247/00

17 Specific Conditions of Use

1. For replacement purposes the cover fixing screws shall be of stainless steel grade A2-70 or stronger
2. Painting and surface finishes, other than those applied by the manufacturer, are not permitted
3. When the unit is used in dust atmospheres the cable entries used shall be sealed to maintain the IP6X rating, in accordance with the applicable installation codes.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

Number	Issue	Date	Description
# 399-101 Sheets 1 to 3	A	22/11/2013	General Arrangement, DB4B Speaker
# 419-107	A	22/11/2013	General Arrangement, DB3B Sounder
* 399-103	A	14-10-13	Certification Labels, DB4B Ex d & Ex tb Speaker

Number	Issue	Date	Description
* 419-110	A	14-10-13	Certification Labels, DB3B Ex d & Ex tb Sounder
^ 419-177	A	22/11/2013	Pressed Wire Element, Extra Fine Mesh

Drawing common to this certificate and IECEX BAS 13.0112X, IECEX BAS 13.0113X, IECEX BAS 13.0114X and IECEX BAS 13.0115X together with Baseefa13ATEX0229X, Baseefa13ATEX0232X and Baseefa13ATEX0233X and held on IEC Ex BAS13.0112X

* Drawing common to this certificate and IECEX BAS 13.0113X. and held on the latter

^ Drawing common to this certificate and IECEX BAS 13.0113X, IECEX BAS 13.0115X and Baseefa13ATEX0233X. and held on IEC Ex BAS13.0113X

1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number:** Baseefa13ATEX0231X/1
- 4 Equipment or Protective System:** Type DB3B GD Sounder & DB4B GD Loudspeaker
- 5 Manufacturer:** Cooper MEDC Limited
- 6 Address:** Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB
- 7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa13ATEX0231X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. 0676

Project File No. 14/0221

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.


SGS Baseefa Limited

Rockhead Business Park, Sladen Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR
GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0231X/1

15 **Description of the variation to the Equipment or Protective System**

Variation 1.1

An increase in the maximum pore size of the fine mesh stainless steel pressed wire element.

16 **Report Number**

Baseefa Confidential Report No. GB/BAS/ExTR14.0082/00

17 **Specific Conditions of Use**

None additional to those listed previously

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Issue	Date	Description
419-177	B	10/03/14	Pressed wire Element, Extra Fine Mesh, Basket Weave

This drawing is common to IECEx BAS 13.0113X, IECEx BAS 13.0115X and Baseefa13ATEX0233X.

1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa13ATEX0231X/2**

4 Equipment or Protective System: **Type DB3B GD Sounder & DB4B GD Loudspeaker**

5 Manufacturer: **Copper MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft, Sutton-in-Ashfield, NG17 5FB**

7 This supplementary certificate extends EC – Type Examination Certificate No. **Baseefa13ATEX0231X** to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. **0676**

Project File No. **14/0862**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number Baseefa13ATEX0231X/2**

15 **Description of the variation to the Equipment or Protective System**

Variation 2.1

To allow the correction of note 3 on drawing number 419-177, so as to adjust the minimum sinter weight from 18.3g to 16.4g. This has no effect upon the explosion type of protections offered by the equipment.

16 **Report Number**

Baseefa certification report: GB/BAS/ExTR14.0314/00

17 **Specific Conditions of Use**

See previous certificates.

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Sheet	Issue	Date	Description
*419-177	1 of 1	C	16/10/14	SINTER SS MESH IIC+IIIC CERETIFED DRAWING

*This drawing is common to this certificate and IECEX BAS 13.0113X, IECEX BAS 13.0115X and Baseefa13ATEX0233X and is held on IECEX BAS 13.0113X.

1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa13ATEX0231X/3**

4 Equipment or Protective System: **Type DB3B GD Sounder & DB4B GD Loudspeaker**

5 Manufacturer: **Cooper MEDC Limited**

6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa13ATEX0231X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. 0676

Project File No. 15/0646

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN


R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa13ATEX0231X/3

15 Description of the variation to the Equipment or Protective System

Variation 3.1

To permit the amendment to change the terminal conductor size from 3.5mm² to 4mm².

Variation 3.2

Minor admin changes to the drawings not affecting certification.

16 Report Number

SGS Baseefa Report Number GB/BAS/ExTR15.0256/00

17 Specific Conditions of Use

None additional to those listed previously

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
399-101	1 to 3	C	04/09/2015	DB4B EXD Speaker, General Assembly

This drawing is common to Baseefa13ATEX0229X, Baseefa13ATEX0231X, Baseefa13ATEX0232X, Baseefa13ATEX0233X and IECEx BAS 13.0115X, IECEx BAS 13.0114X, IECEx BAS 13.0113X and IECEx BAS 13.0112X and held with the latter.