

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F0762

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

XB15 Conventional Visual Alarm Device Type B (red light) *(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trade mark of:

Eaton MEDC Ltd
Unit B, Sutton Parkway
Oddicroft Lane
Sutton-In-Ashfield
NG17 5FB
United Kingdom

Eaton MEDC Ltd
Unit B, Sutton Parkway
Oddicroft Lane
Sutton-In-Ashfield
NG17 5FB
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 November 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2019

Date of Issue: 5 November 2019

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0762

XB15 Conventional Visual Alarm Device Type B (red light)

Notes:

- 1) The VAD does not contain a function for synchronicity between devices.
- 2) The VAD is rated as C-3-16, C-6-6 and W-3-5.
- 3) The VAD must only be used with the red lens and is only approved for the 24V d.c. version, at 1Hz flash rate and must not be used with a lens guard.
- 4) When used as a wall mounted VAD the device must be installed in accordance with the guidance given in TM250.



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2019

Date of issue: 5 November 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie