

## BRE Global

### Notified Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance

### 0832-CPR-F0761

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### **XB15 Conventional Visual Alarm Device Type B (white light)**

*(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trade mark of:

**Eaton MEDC Ltd**  
**Unit B, Sutton Parkway**  
**Oddicroft Lane**  
**Sutton-In-Ashfield**  
**NG17 5FB**  
**United Kingdom**

and produced in the manufacturing plant(s):

**Eaton MEDC Ltd**  
**Unit B, Sutton Parkway**  
**Oddicroft Lane**  
**Sutton-In-Ashfield**  
**NG17 5FB**  
**United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### **EN 54-23:2010 - Visual alarm devices**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 20 August 2014 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 20 August 2014

Date of Issue: 19 July 2017

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

**BRE Global Limited**

Bucknalls Lane,  
Garston, Watford,  
Hertfordshire, UK,  
WD25 9XX

**Notified Body No. 0832**

Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-CPR-F0761**

**XB15 Conventional Visual Alarm Device Type B (white light)**

**Notes:**

- 1) The VAD does not contain a function for synchronicity between devices.
- 2) The VAD is rated as C-3-32, C-6-31, C-9-12 and W-8-13.
- 3) The VAD must only be used with the clear lens and is only approved for the 24V d.c. version, at 1Hz flash rate and must not be used with a lens guard.
- 4) When used as a wall mounted VAD the device must be installed in accordance with the guidance given in TM250.



P Halligan, Certification Manager,  
On behalf of BRE Global Limited

Date of First Issue: 20 August 2014

Date of Issue: 19 July 2017

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).