



Certificate of Compliance

Certificate: 70008955 (LR 79120-3)

Master Contract: 178434

Project: 70008955

Date Issued: October 21, 2014

Issued to: Cooper MEDC Ltd.

Unit B Sutton Parkway
Oddicroft Lane
Sutton-in-Ashfield, NG17 5FB
United Kingdom
Attention: Brian Taylor

The products listed below are eligible to bear the CSA Mark shown



Gino Surace

Issued by: Gino Surace

PRODUCTS

CLASS 3428 03 - FIXTURES AND FITTINGS - For Hazardous Locations

Class I, Groups A, B, C and D

Model PBI Pushbutton Unit, supply 24VDC max, 2A max; intrinsically safe when connected through CSA Certified zener barrier rated 28V max, 300 ohm min or 22V max, 150 ohm min. Temperature code T4A; CSA Enclosure Type 4.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 94-M91	Special Purpose Enclosures
CAN/CSA C22.2 No. 142-M1987	Process Control Equipment
CAN/CSA C22.2 No. 157-M1987	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations
CAN/CSA C22.2 No. 157-92	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

MARKINGS

See Descriptive Report