

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1691:103

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Cooper MEDC, 3413 N. Sam Houston Pkwy West, Houston, TX 77086  
Contact: Joel Weinberg (713) 280-3461 Fax (713) 937-9773  
[joel.weinberg@cooperindustries.com](mailto:joel.weinberg@cooperindustries.com)

**DESIGN:** Models XB16 strobe warning light. Suitable for indoor and outdoor, Class I, Div. 2, Groups A, B, C, D, Class II, Div. 2, F, G. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 580,000 candela  
NEMA 4x and 6

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as strobe warning light for use with separately listed compatible fire alarm control units. Suitable for indoor and outdoor, Class I, Div. 2, Groups A, B, C, D, Class II, Div. 2, Groups F, G.

**NOTE:** Not suitable for the hearing impaired application

05-27-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division