

# Certificate of Compliance

Certificate Number 20071116-E187688  
Report Reference E187688, 2001 January 17  
Issue Date 2007 November 16

Page 1 of 1



*Issued to:* **Medc**  
Colliery Rd, Pinxton, Nottingham  
NG16 6JF England, United Kingdom


*This is to certify that representative samples of* **Audible-Signal Devices**  
Model DB1 for use in Class I, Division 1, Groups C and D hazardous locations.

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* UL 464, Seventh Edition, Suitable for Fire Alarm Applications.  
UL 1203, Fourth Edition.

*Additional Information:* Marking shall include the Listee's Name, Model Number, Electrical Ratings including voltage, and amps, Ambient Range and Temperature Code.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Russell L. Filip*  
Russell L. Filip/Staff Engineer  
Underwriters Laboratories Inc.

Reviewed by: *Paul T. Kelly*  
Paul T. Kelly/Operations Manager  
Underwriters Laboratories Inc.