



国家防爆

Electrical Apparatus for Explosive Atmospheres

# CERTIFICATE OF CONFORMITY

Cer. No.: CNEx14.2516X

**Manufacturer** Eaton MEDC Ltd  
(Address: Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG 17 5FB, United Kindom)

**Name of Product** Sounder

**Type of Product** DB3BE G

**Marking** Ex de IIC T4/T5/T6 Gb

**Standard** \_\_\_\_\_

**Drawing No.** 419-107~108

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

- GB3836.1-2010 Explosive atmospheres Part 1: Equipment-General requirements
- GB3836.2-2010 Explosive Atmospheres Part 2: Equipment protection by flameproof enclosures "d"
- GB3836.3-2010 《Explosive atmospheres-Part 3: Equipment protection by increased safety "e"》

**Note** See Annex.

**Valid Date** From December 28, 2016 to September 14, 2019

**Issue Date** December 28, 2016

**Director**



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

**Address:** No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
**Tel:** 0377-63258564 **Fax:** 0377-63208175 **Http://www.china-ex.com**

**Note:** This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).

登陆网站 输入数码 查询真伪 9478 8026 2382 4849 查询方式: www.china-ex.com





国家防爆

Electrical Apparatus for Explosive Atmospheres

# CERTIFICATE OF CONFORMITY

Cer. No.: CNEx14.2516X

1. The product has been certified according to ATEX.  
Certificate no: Baseefa13ATEX 0232X
2. This certification is updated version due to the name change of the manufacturer.
3. The related information of this product are as follows:

Type	Maximum Rated voltage	Watts	Temperature Classification	Ambient Temperature Range
DB3BE G	254V	15	T4	-50°C to +70°C
			T5	-50°C to +55°C
			T6	-50°C to +40°C

4. For replacement purposes the cover fixing screws shall be of stainless steel grade A2-70 or stronger.
5. Painting and surface finishes, other than those applied by the manufacturer, are not Permitted.
6. Not more than one single or multiple strand wiring lead shall be connected into either side of any terminal, unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
7. Leads connected to the terminals shall be insulated for at least 275V and this insulation shall extend to within 1mm of the metal of the terminal throat.
8. Minimum creepage and clearance distances between the terminals and adjacent conductive parts(including cable entry devices) must be at least 6mm.
9. All terminal screws, used and unused, shall be tightened down.

Issue Date    December 28, 2016

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
Tel: 0377-63258564    Fax: 0377-63208175    Http://www.china-ex.com

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).