

CERTIFICATE OF COMPLIANCE

Certificate Number 20151123-4786980667-
Report Reference E187894-20151123-Description
Issue Date 2015-November-23

Issued to: Cooper MEDC |
Sutton Parkway, Oddicroft Lane
Sutton-In-Ashfield, NG17 5FB, GB |

**This is to certify that
representative samples of** Xenon Beacon |
XB15AC |

Have been investigated by UL in accordance with the
Standards indicated on this Certificate.

Standard(s) for Safety: IEC 61508: 2010, "Functional safety of
electrical/electronic/programmable electronic safety-related
systems", 2nd Edition |

Bruce A. Mahrenholz, CPO Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20151123-4786980667-
Report Reference E187894-20151123-Description
Issue Date 2015-November-23

Additional Information: Complies with the requirements for the following functional safety ratings:

- SIL Capability 1, as defined by IEC 61508:2010
- Safety integrity data:

HFT = 0

SFF = 71.9%

PFH = 3.48e-7/h

PFD = 1.53e-3 (proof test interval of 8760h)

λ_S = 884.41 FIT

λ_{DD} = 6.5 FIT

λ_{DU} = 348.34 FIT


In a redundant installation and redundant mode of use of two units of XB15AC, SIL 2 capability regarding architectural integrity and systematic capability can be achieved. The PFH or PFD value is to be calculated and verified based on installation and operational profile.

The product must be installed, operated, and maintained, in accordance with the instructions for use. See the UL Online Certifications Directory at www.ul.com/database for additional information.

Reviewed by:



Thomas Maier
Principal Engineer



Jason R. Smith
Staff Engineer

Bruce A. Mahrenholz, CPO Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

