

Certificate of Product Approval

Certificate Number: 1120b

Issue: 03

Eaton MEDC Ltd

Unit B, Sutton Parkway
Oddicroft Lane
Sutton-in-Ashfield
NG17 5FB
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Visual Alarm Devices

XB15 (White)

XB15 (Red)

(refer to Appendix for details)

Standards

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

19 July 2017

Date of Issue

14 June 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1120b

Issue: 03

Eaton MEDC Ltd

Certified Product	Description	LPCB Ref.No.
XB15 (White)	<p>Conventional Visual Alarm Device Type B (white light)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The VAD does not contain a function for synchronicity between devices. 2. The VAD is rated as C-3-32, C-6-31, C-9-12 and W-8-13. 3. The VAD must only be used with the clear lens and is only approved for the 24V d.c. version, at 1Hz flash rate and must not be used with a lens guard. 4. When used as a wall mounted VAD the device must be installed in accordance with the guidance given in TM250. 	1120b/01
XB15 (Red)	<p>Conventional Visual Alarm Device Type B (red light)</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. The VAD does not contain a function for synchronicity between devices. 2. The VAD is rated as C-3-16, C-6-6 and W-3-5. 3. The VAD must only be used with the red lens and is only approved for the 24V d.c. version, at 1Hz flash rate and must not be used with a lens guard. 4. When used as a wall mounted VAD the device must be installed in accordance with the guidance given in TM250. 	1120b/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

19 July 2017

Date of Issue

14 June 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


