



---

---

## CERTIFICATE OF TEST

**Date of issue:** 23 March 2009                      **Project number:** 09/0148  
**Applicant:** Cooper MEDC Limited                      **Reference:** 0676  
**Address:** Pinxton                      **Test record sheet:** TR09/0148/01  
Nottingham  
NG16 6JF

### Description of Test Sample

Type SL5/4 Serial Number 5568238 10 01

### Drawings

N/A

### Specification

To test the unit to IP 66 and IP 67 as per IEC 60529

### Result

The unit passed the criteria for IP 66 and IP 67

### Comments


Test carried out by: M. Needham

Checked and approved by: P. Dickie

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.



**Baseefa**  
Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

  
R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa