



Certificate of Test

*We hereby declare that the item described below
has been tested by BSI and
complies with the requirements of*

*BS EN 60598-1:1997 & BS EN 60529:1992 for a classification
of IP66 (dust tight/jet proof) & IP67 (dust tight/water tight)*

*The full details of the tests and the results are given in
our Report No: 246/005302 Dated: 16 December 1998*

Description of item tested:

One sample of a Xenon beacon luminaire model reference XB9

*Submitted by: MEDC
Colliery Road
Pinxton
Nottingham
NG16 6JF*

Certificate Number: 246/005302 Issue 2

Certificate authorised by:

P.R. Overington

P R Overington

Title

Team Leader

Date

16 December 1998

Attention is drawn to the conditions upon which this declaration is issued, namely:

1. The general and specific conditions of the BSI Product Services Test Leaflet 1 apply in all respects. Copies of this leaflet are available on request.

2. This Declaration applied only to the particular sample tested and to the specific tests carried out as detailed in the Report referred to above.

3. This declaration does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.

BSI Product Services, Maylands Avenue, Hemel Hempstead, Hertfordshire HP2 4SQ