



CERTIFICATE OF TEST

Date of issue: 6th January 2006

Project number: 05/0509

Applicant: MEDC Limited

Reference: 0676

Address: Colliery Road
Pinxton
Nottinghamshire
NG16 9JF

Test record sheet: 05/0509/01 to 03 inclusive

Description of Test Samples

Various sounders and beacons as listed below

Specification

BS EN 60529: 1992

Result

The various sounders and beacons passed the tests for the Ingress Protection (IP) ratings given below:

XB10 - IP66	XB13 - IP66	XB15 - IP66 & IP67	XB16 - IP66 & IP67
DB5 - IP65	DB12 - IP66 & IP67	DB15 - IP66 & IP67	DB10 - IP66 & IP67
DB16 - IP66	DB18 - IP66 & IP67		

In addition:

Samples of the DB7 and DB 14 were also submitted and found to be of identical construction to the DB12 and DB15 respectively and so may be ascribed the following IP ratings:

DB7 - IP66 & IP67 **DB14 - IP66 & IP67**

Test carried out by: Miles Needham

Checked and approved by: Peter Dickie

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

Baseefa

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com
Baseefa is a trading name of Baseefa (2001) Ltd
Registered in England No. 4305578 at the above address

R S SINCLAIR
DIRECTOR
On behalf of
Baseefa (2001) Ltd.