

# Certificate of Test

We hereby declare that the item described below  
has been tested by BSI and  
complies with the requirements of

BS EN 60529:1992 for a classification of IP66  
Dust-tight/Protected against powerful water jets

The full details of the tests and the results are given  
in our Report No: LS000946 Dated: 25 November 1994


## Description of item tested:

One MEDC DB1 Sounder  
reference 173351

## Submitted by:

MEDC  
Colliery Road  
Brookhill Industrial Estate  
Pinxton  
Nottingham  
NG16 6JF

## Certificate authorized by:



pp D H Price

Title

Manager: Lighting Technology Laboratories

Date

25 November 1994



TESTING

Attention is drawn to the conditions upon which this declaration is issued,  
namely:

1 The general and specific conditions of the BSI Test House, Test Leaflet 1  
apply in all respects. Copies of this leaflet are available on request.

2 This Declaration applies only to the particular sample tested and to the  
specific tests carried out as detailed in the report referred to above.

3 This declaration does not indicate any measure of Approval, Certification,  
Supervision, Control or Surveillance by BSI to this or any related

For the Director, BSI Testing, Maylands Avenue, Hemel Hempstead, Hertfordshire HP2 4SQ