



# Certificate of Compliance

Certificate: 2689075(LR79122)

Master Contract: 178434

Project: 2689075

Date Issued: January 17, 2014

Issued to: Cooper MEDC Ltd.

Unit B Sutton Parkway  
Oddicroft Lane  
Sutton-in-Ashfield, NG17 5FB  
United Kingdom  
Attention: Brian Taylor

*The products listed below are eligible to bear the CSA Mark shown*



*Jelena Dzeletovic*

Issued by: Jelena Dzeletovic

## PRODUCTS

**CLASS 3428 03** - FIXTURES AND FITTINGS - For Hazardous Locations

Class I Group D:

Series SM87 Pushbutton Stations, Models SM87BGLD, SM87LBGLD, SM87PBLD and SM87PBMD, rated 24V ac/dc, 2A, Type 4.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-10 -Industrial Control Equipment

CSA Std - C22.2 No. 30-M1986 (R2012) -Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 -Special Purpose Enclosures



## *Supplement to Certificate of Compliance*

Certificate: 2689075(LR79122)

Master Contract: 178434

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2689075	Jan 17, 2014	Update to report LR 79122-4 to increase the upper ambient temperature to +55°C to series SM87 push buttons stations.

#### **History**

LR 79122-4	August 25, 1998	Original Certification
------------	-----------------	------------------------