

CERTIFICATE OF TEST

Applicant: Cooper MEDC Limited

Project number: 15/0567

Address: Unit B, Sutton Parkway,
Oddicroft Lane, Sutton-in-Ashfield,
NG17 5FB

Customer Reference No: 0676

Test record sheet: TR/15/0567/01

Description of Test Sample

The PB Call Point enclosure includes a body, cover and a plunger located through the cover. The enclosure is constructed in moulded GRP (Glass Fibre Reinforced) material. The cover is fixed to the body using four threaded fasteners. The plunger has a lift and push flip cap. There is an o-ring seal between the cover and body, between the plunger shaft and covers, and between the LED housing and cover. The enclosure is 126x116x120mm (LxWxH)

Drawings

Drawing No.	Sheet	Issue	Date	Description
480-412	1 OF 1	A	28-08-15	PBE/I/W CALL POINT SEALING DETAIL

Specification

To test the enclosure as above, for ingress protection level IP66 and IP67 in accordance with IEC60529.

Result

There was no dust or water ingress, therefore meeting the criteria for both IP66 and IP67.

Comments

Test carried out by: S Mashanga


Checked and approved by: D Brearley

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



SGS Baseefa Limited
Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298
766601 e-mail info@baseefa.com web site
www.baseefa.com

Registered in England No. 4305578.
Registered address: Rossmore Business Park, Ellesmere Port, Cheshire,


R S SINCLAIR
GENERAL MANAGER
On behalf of SGS Baseefa Limited