

Certificate of Compliance

Certificate Number 20071116-E186629
Report Reference E186629, 2000 November 7
Issue Date 2007 November 16

Page 1 of 1



Issued to: **Medc**
Colliery Rd, Pinxton, Nottingham
NG16 6JF England, United Kingdom


This is to certify that representative samples of **Fire Alarm Devices**
Model SM87 followed by PBL for use in Class I, Division 1, Groups C and D Hazardous Locations.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 38, Seventh Edition; UL 1203, Fourth Edition; CSA-C22.2 No. 30-1986; CSA-C22.2 No. 205-1983

Additional Information: Marking shall include the Listee's name, device model designation, optional ambient temperature range and electrical ratings including voltage and current.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Russell L. Filip*
Russell L. Filip/Staff Engineer
Underwriters Laboratories Inc.

Reviewed by: *Paul T. Kelly*
Paul T. Kelly/Operations Manager
Underwriters Laboratories Inc.