


Certificate of Compliance

Certificate Number 20091023-E320282
Report Reference E320282-20080505
Issue Date 2009 October 23

Page 1 of 1



Issued to: **MEDC**
Colliery Rd, Pinxton, Nottingham, NG16 6JF United Kingdom

This is to certify that representative samples of

Non-Coded Fire Alarm Boxes

Model Series SM87PBL, for use in Class I, Groups C and D, Class I, Zone 1, Groups IIA and IIB Hazardous Locations.

Have been investigated by Underwriters Laboratories of Canada in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

The products described herein have been investigated to, and found in compliance with, Manual Stations for Fire Alarm Systems, Including Accessories, CAN/ULC-S528-05, and CAN/CSA C22.2 No. 30-M1986.

Additional Information:

Electrical: 24 V dc/ac, 2 A, without LED; 24 V dc/ac, 7-30 mA, with LED
Ambient: -40 to 70°C without LED (for indoor and outdoor use only);
-20 to 70°C with LED (for indoor use only)

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the current status, validate the above information via the on-line directory.

Look for the ULC Listing Mark on the product

Issued by: *William Liang*
William Liang, Engineering Associate
Underwriters' Laboratories of Canada

Reviewed by: *Alfred Siu*
Alfred Siu, Engineer Team Leader
Underwriters' Laboratories of Canada