

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170809-E187894  
**Report Reference** E187894-20080627  
**Issue Date** 2017-AUGUST-09

**Issued to:** Eaton MEDC Ltd  
UNIT B  
SUTTON PARKWAY, ODDICROFT LANE  
SUTTON-IN-ASHFIELD  
NG17 5FB UNITED KINGDOM


**This is to certify that  
representative samples of**

VISUAL-SIGNAL APPLIANCES FOR USE IN  
HAZARDOUS LOCATIONS CERTIFIED FOR CANADA  
CNL - Visual Signal Appliances, model series XB15 and  
model series LD15 suitable for indoor and outdoor use only,  
for use in Hazardous Locations: Ex db IIC Gb, and Class II,  
Division 2, Groups F and G.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** SEE ADDENDUM PAGE FOR STANDARDS  
**Additional Information:** See the ULC Online Certification Directory at [www.ulc.ca](http://www.ulc.ca)  
for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's  
Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with  
the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product  
category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized  
licensee of ULC. For questions, please contact a local ULC Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE


**Certificate Number** 20170809-E187894  
**Report Reference** E187894-20080627  
**Issue Date** 2017-AUGUST-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

CAN/ULC-S526-07, Visual Signal Devices for Fire Alarm Systems Including Accessories.  
CAN/CSA C22.2 No. 157-92 - Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations.

CAN/CSA-C22.2 No. 60079-0:15 - Explosive atmospheres — Part 0: Equipment — General requirements.

CAN/CSA-C22.2 No. 60079-1:16 - Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d”



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

