

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-1691:101

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Cooper MEDC, 3413 North Sam Houston Pkwy West, Houston, TX 77086  
Contact: Joel Weinberg (713) 937-9772 Ext. 104 FAX (713) 937-9773  
[joel.weinberg@cooperindustries.com](mailto:joel.weinberg@cooperindustries.com)

**DESIGN:** Models XB 11 Range and XB12 Range beacon/strobes explosion proof. Model XB11 Range is a 5 joule xenon strobe. Model XB12 Range is a 21 joule xenon stobe. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** XB11 Range: 22, 000 candela  
XB12 Range: 124, 000 candela

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as strobes for use with separately listed compatible fire alarm control units. Suitable for outdoor and in Class I Division 2, Groups C and D, Class I, Zone 1 & 2, AExd IIB T4/T5 hazardous locations. Refer to listee's Installation Instruction Manual for details.

06-26-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division