

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170809-E187894  
**Report Reference** E187894-20040806  
**Issue Date** 2017-AUGUST-09

**Issued to:** Cooper MEDC Ltd  
Unit B, Sutton Parkway, Oddicroft Lane  
Sutton-In-Ashfield, Ng17 5fb United Kingdom

**This is to certify that  
representative samples of**

VISUAL-SIGNAL APPLIANCES FOR USE IN ZONE  
CLASSIFIED HAZARDOUS LOCATIONS

Refer to Addendum Page for Models/Product

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 60079-0, 6th Ed., UL 60079-1, 6th Ed, ANSI/ISA  
12.12.01-2013, CAN/CSA C22.2 No. 157-92, 3rd Ed.  
CAN/CSA C22.2 No. 213-M1987, 1st Ed, CAN/CSA-C22.2  
No. 60079-0:15, 3rd Ed, CAN/CSA-C22.2 No. 60079-1:16,  
3rd Ed, UL 1638, 4th Ed, CSA C22.2 No. 205-12, 2nd Ed.

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170809-E187894  
**Report Reference** E187894-20040806  
**Issue Date** 2017-AUGUST-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL Visual Signal Appliances, Beacon Model number designation XB15, FB15 and LD15 for use in Class I, Zone 1 AEx d IIC and Class I, Zone 1 AEx d IIB Hazardous Locations.

CNL Visual Signal Appliances, Beacon Model number designation XB15, FB15 and LD15 for use in Class I, Zone 1 Ex d IIC Hazardous Locations.

Model number designation XB15 and LD15 may also be marked for use in Class II, Division 2, Groups F and G.

Equipment marked Class I, Zone 1 AEx d IIC may additionally be marked Class I, Division 2, Group A and B Hazardous Locations.


Equipment that can be marked Group A and B may alternatively be marked Group A, B, C, and D or any combination of these groups.

Equipment marked Class I, Zone 1 AEx d IIB may additionally be marked Class I, Division 2, Group C Hazardous Locations.

Equipment that can be marked Group C may alternatively be marked Group C and D or any combination of these groups.

Equipment marked Ex d IIB may additionally be marked Class I, Division 2, Group C Hazardous Locations.

Equipment that can be marked Group C may alternatively be marked Group C and D or any combination of these groups



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

